



June 11, 2020  
DVP-200013

Mr. David Jones  
Air Pollution Control Officer  
South Coast Air Quality Management District  
21865 East Copley Drive  
Diamond Bar, California 91765-4182

Subject: Monthly Report of Excess Emissions for May 2020  
  
SCAQMD FILE # 100154

Dear Mr. Jones:

Excess emissions summaries for each boiler for May 2020 are attached.

Emission concentration limits (ppm) do not apply during the normal start up and shut down conditions for each boiler. Thus, exceedances within the permit limits during start up and shut down, as defined in the amendment, are not applicable and as such not reportable.

Please call if you have any questions or comments. I can be reached at (760) 262-1600.

Sincerely,

A handwritten signature in black ink, appearing to read "Jim Robertson".

Jim Robertson  
Plant Manager



Page 2

encl

cc:

Chief, Stationary Source Division

California Air Resources Board

P.O. Box 2815

Sacramento, CA 95814

Director, Air Management Division

Attention: Air-5

U.S. Environmental Protection Agency

75 Hawthorne Street

San Francisco, CA 94105-3901

**BOILER #1**  
**May 2020**

Boiler Number	Quarterly Report Code	Excess Emission number	Reading at 3% O <sub>2</sub>						
			Date	Limit Exceeded	Duration (hrs)	Average Value	Maximum Value	Permit Limit	Comments
			CEMS			CEMS			CEMS
			5/5/2020	Nox ppm@3%O <sub>2</sub>	1				CEM taken out of service for maintenance.
			5/8/2020	Nox ppm@3%O <sub>2</sub>	4				CEM taken out of service for maintenance.
			5/16/2020	Nox ppm@3%O <sub>2</sub>	22				CEM taken out of service for maintenance.
			5/17/2020	Nox ppm@3%O <sub>2</sub>	5				CEM taken out of service for maintenance.
			5/28/2020	Nox ppm@3%O <sub>2</sub>	4				CEM taken out of service for maintenance.
			5/29/2020	Nox ppm@3%O <sub>2</sub>	5				CEM taken out of service for maintenance.
			5/5/2020	Nox lb/mmbtu	1				CEM taken out of service for maintenance.
			5/8/2020	Nox lb/mmbtu	4				CEM taken out of service for maintenance.
			5/16/2020	Nox lb/mmbtu	22				CEM taken out of service for maintenance.
			5/17/2020	Nox lb/mmbtu	5				CEM taken out of service for maintenance.
			5/28/2020	Nox lb/mmbtu	4				CEM taken out of service for maintenance.
			5/29/2020	Nox lb/mmbtu	5				CEM taken out of service for maintenance.
			5/8/2020	NOx lb/hr	4				CEM taken out of service for maintenance.
			5/16/2020	NOx lb/hr	22				CEM taken out of service for maintenance.
			5/17/2020	NOx lb/hr	5				CEM taken out of service for maintenance.
			5/28/2020	NOx lb/hr	4				CEM taken out of service for maintenance.
			5/29/2020	NOx lb/hr	5				CEM taken out of service for maintenance.
			5/5/2020	So <sub>2</sub> ppm@3%O <sub>2</sub>	1				CEM taken out of service for maintenance.
			5/8/2020	So <sub>2</sub> ppm@3%O <sub>2</sub>	4				CEM taken out of service for maintenance.
			5/16/2020	So <sub>2</sub> ppm@3%O <sub>2</sub>	22				CEM taken out of service for maintenance.
			5/17/2020	So <sub>2</sub> ppm@3%O <sub>2</sub>	5				CEM taken out of service for maintenance.
			5/28/2020	So <sub>2</sub> ppm@3%O <sub>2</sub>	4				CEM taken out of service for maintenance.
			5/29/2020	So <sub>2</sub> ppm@3%O <sub>2</sub>	5				CEM taken out of service for maintenance.
			5/5/2020	So <sub>2</sub> lb/mmbtu	1				CEM taken out of service for maintenance.
			5/8/2020	So <sub>2</sub> lb/mmbtu	4				CEM taken out of service for maintenance.
			5/16/2020	So <sub>2</sub> lb/mmbtu	22				CEM taken out of service for maintenance.
			5/17/2020	So <sub>2</sub> lb/mmbtu	5				CEM taken out of service for maintenance.
			5/28/2020	So <sub>2</sub> lb/mmbtu	4				CEM taken out of service for maintenance.
			5/29/2020	So <sub>2</sub> lb/mmbtu	5				CEM taken out of service for maintenance.
			5/8/2020	So <sub>2</sub> lb/hr	4				CEM taken out of service for maintenance.
			5/16/2020	So <sub>2</sub> lb/hr	22				CEM taken out of service for maintenance.
			5/17/2020	So <sub>2</sub> lb/hr	5				CEM taken out of service for maintenance.
			5/28/2020	So <sub>2</sub> lb/hr	4				CEM taken out of service for maintenance.
			5/29/2020	So <sub>2</sub> lb/hr	5				CEM taken out of service for maintenance.
			5/5/2020	CO ppm@3%O <sub>2</sub>	1				CEM taken out of service for maintenance.
			5/8/2020	CO ppm@3%O <sub>2</sub>	4				CEM taken out of service for maintenance.
			5/16/2020	CO ppm@3%O <sub>2</sub>	22				CEM taken out of service for maintenance.
			5/17/2020	CO ppm@3%O <sub>2</sub>	5				CEM taken out of service for maintenance.
			5/28/2020	CO ppm@3%O <sub>2</sub>	4				CEM taken out of service for maintenance.
			5/29/2020	CO ppm@3%O <sub>2</sub>	5				CEM taken out of service for maintenance.
			5/8/2020	CO lb/hr	4				CEM taken out of service for maintenance.
			5/16/2020	CO lb/hr	22				CEM taken out of service for maintenance.
			5/17/2020	CO lb/hr	5				CEM taken out of service for maintenance.
			5/28/2020	CO lb/hr	4				CEM taken out of service for maintenance.
			5/29/2020	CO lb/hr	5				CEM taken out of service for maintenance.

**NOTE:** 1. The term ALL is used in the Limit Exceeded column to indicate the following:  
(Nox ppm, Nox lb/hr, Co ppm, Co lb/hr, So2 ppm, & So2 lb/hr)

**BOILER #2**  
**April 2020**

Hours Operated: 542  
hrs

[illegible]

**NOTE:** 1. The term ALL is used in the Limit Exceeded column to indicate the following:  
(Nox ppm, Nox lb/hr, Co ppm, Co lb/hr, So2 ppm, & So2 lb/hr)

**STACK**  
**April 2020**

[illegible]

NOTE: 1. The term ALL is used in the Limit Exceeded column to indicate the following:  
(Nox ppm, Nox lb/hr, Co ppm, Co lb/hr, So2 ppm, & So2 lb/hr)